

Quantum Profile Systems Ltd
t/a Dacatie Green Building Solutions

Salmon Fields
Royton
Oldham
Lancashire OL2 6JG

Tel: 0161 627 4222 Fax: 0161 627 4333

e-mail: info@dacatie.co.uk

website: www.dacatie.co.uk



Agrement Certificate

98/3474

Product Sheet 1

DACATIE INSULATED PVC-U CAVITY CLOSERS


**DACATIE SUPAFIX (SF), SUPAFIX FIRE RATED (SFR) AND SUPERFIX MULTICLOSER
INSULATED PVC-U CAVITY CLOSERS**

This Agrément Certificate Product Sheet⁽¹⁾ relates to Dacatie Supafix (SF), Supafix Fire Rated (SFR) and Supafix Multicloser Insulated PVC-U Cavity Closers, for use as cavity closers (cavity width 50 to 110 mm) in masonry cavity walls.

(1) Hereinafter referred to as 'Certificate'.

CERTIFICATION INCLUDES:

- factors relating to compliance with Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.



KEY FACTORS ASSESSED

Hygrothermal behaviour — the products meet and exceed the minimum thermal resistance path of $0.45 \text{ m}^2 \cdot \text{K} \cdot \text{W}^{-1}$ as required by the Accredited Construction Details. Default ψ -values (psi) in BRE Information Paper IP 1/06 may, therefore, be used for jamb and sill junctions in SAP or SBEM calculations (see section 6).

Weather resistance — the products are effective as a damp-proof barrier and, when used in a suitable wall construction, will resist the passage of water into the interior of the building in flush and check reveal installations (see section 7).

Structural stability — in terms of wind loading resistance, the products can be used in all areas of the UK. The products must not be used to support loads from the masonry (see section 8).

Properties in relation to fire — Dacatie Supafix Fire Rated (SFR) cavity closers can contribute to a construction satisfying the requirements of the national Building Regulations (see section 9).

Durability — the cavity closer profiles, protected within the cavity, will continue to function for the normal expected life of the building in which they are installed (see section 11).



The BBA has awarded this Certificate to the company named above for the products described herein. These products have been assessed by the BBA as being fit for their intended use provided they are installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Date of Third issue: 14 September 2020

Originally certificated on 20 March 1998

Hardy Giesler
Chief Executive Officer

The BBA is a UKAS accredited certification body – Number 113.

*The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk
Readers MUST check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA directly.*

Any photographs are for illustrative purposes only, do not constitute advice and should not be relied upon.

British Board of Agrément

Bucknalls Lane
Watford
Herts WD25 9BA

tel: 01923 665300
clientservices@bbacerts.co.uk
www.bbacerts.co.uk

©2020

Regulations

In the opinion of the BBA, Dacatie Supafix (SF), Supafix Fire Rated (SFR) and Supafix Multicloser Insulated PVC-U Cavity Closers, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements of the following Building Regulations (the presence of a UK map indicates that the subject is related to the Building Regulations in the region or regions of the UK depicted):



The Building Regulations 2010 (England and Wales) (as amended)

Requirement: B3(4) Comment:	Internal fire spread (structure) Dacatie Supafix Fire Rated (SFR) closers can contribute to a construction satisfying this Requirement. See section 9.2 of this Certificate.
Requirement: C2(b) Comment:	Resistance to moisture The products have adequate resistance to the ingress of rain and wind-driven spray and so can contribute towards the wall satisfying this Requirement. See section 7 of this Certificate.
Requirement: C2(c) Comment:	Resistance to moisture The products will not constitute a significant condensation risk and so can contribute towards the wall satisfying this Requirement. See sections 6.2 and 6.3 of this Certificate.
Requirement: L1(a)(i) Comment:	Conservation of fuel and power The products can contribute to minimising heat loss at jambs and sills. See section 6.1 of this Certificate.
Regulation: 7(1) Comment:	Materials and workmanship The products are acceptable. See section 11 and the <i>Installation</i> part of this Certificate.
Regulation: 26 Regulation: 26A Regulation: 26A Regulation: 26B Comment:	CO₂ emission rates for new buildings Fabric energy efficiency rates for new dwellings (applicable to England only) Primary energy consumption rates for new buildings (applicable to Wales only) Fabric performance values for new dwellings (applicable to Wales only) The products can contribute to minimising heat loss at jambs and sills. See sections 6.1 and 6.2 of this Certificate.



The Building (Scotland) Regulations 2004 (as amended)

Regulation: 8(1) Comment:	Durability, workmanship and fitness of materials The products can contribute to a construction satisfying this Regulation. See section 11 and the <i>Installation</i> part of this Certificate.
Regulation: 9 Standard: 2.4 Comment:	Building standards applicable to construction Cavities Dacatie Supafix Fire Rated (SFR) closers can contribute to a construction satisfying this Standard, with reference to clause 2.4.1 ⁽¹⁾⁽²⁾ and Annexes 2.B ⁽¹⁾ or 2.D ⁽²⁾ . See section 9.2 of this Certificate.
Standard: 3.10 Comment:	Precipitation The products have adequate resistance to the ingress of rain and wind-driven spray and so can contribute towards the wall satisfying this Standard, with reference to clauses 3.10.1 ⁽¹⁾⁽²⁾ and 3.10.3 ⁽¹⁾⁽²⁾ . See section 7 of this Certificate.

Standard: Comment:	3.15	Condensation The products will not constitute a significant condensation risk and so can contribute towards the wall satisfying this Standard, with reference to clauses 3.15.1 ⁽¹⁾⁽²⁾ , 3.15.4 ⁽¹⁾⁽²⁾ and 3.15.5 ⁽¹⁾⁽²⁾ . See sections 6.2 and 6.3 of this Certificate.
Standard: Standard: Comment:	6.1(b) 6.2	Carbon dioxide emissions Building insulation envelope The products can contribute to minimising heat loss at jambs and sills, with reference to clauses 6.2.3 ⁽¹⁾ , 6.2.4 ⁽¹⁾⁽²⁾ and 6.2.5 ⁽²⁾ . See section 6.1 of this Certificate.
Standard: Comment:	7.1(a)(b)	Statement of sustainability The products can contribute to satisfying the relevant requirements of Regulation 9, Standards 1 to 6, and therefore will contribute to a construction meeting a bronze level of sustainability as defined in this Standard. In addition, the products can contribute to a construction meeting a higher level of sustainability as defined in this Standard, with reference to clauses 7.1.4 ⁽¹⁾⁽²⁾ [Aspects 1 ⁽¹⁾⁽²⁾ and 2 ⁽¹⁾], 7.1.6 ⁽¹⁾⁽²⁾ [Aspects 1 ⁽¹⁾⁽²⁾ and 2 ⁽¹⁾] and 7.1.7 ⁽¹⁾⁽²⁾ [Aspect 1 ⁽¹⁾⁽²⁾]. See section 6.1 of this Certificate.
Regulation: Comment:	12	Building standards applicable to conversions Comments in relation to the products under Regulation 9, Standards 1 to 6, also apply to this Regulation, with reference to clause 0.12.1 ⁽¹⁾⁽²⁾ and Schedule 6 ⁽¹⁾⁽²⁾ . (1) Technical Handbook (Domestic). (2) Technical Handbook (Non-Domestic).



The Building Regulations (Northern Ireland) 2012 (as amended)

Regulation: Comment:	23	Fitness of materials and workmanship The products are acceptable. See section 11 and the <i>Installation</i> part of this Certificate.
Regulation: Comment:	28(b)	Resistance to moisture and weather The products have adequate resistance to the ingress of rain and wind-driven spray and so can contribute towards the wall satisfying this Regulation. See section 7 of this Certificate.
Regulation: Comment:	29	Condensation The products will not constitute a significant condensation risk and so can contribute towards the wall satisfying this Regulation. See section 6.3 of this Certificate.
Regulation: Comment:	35(4)	Internal fire spread — Structure Dacatie Supafix Fire Rated (SFR) closers can contribute to a construction satisfying this Regulation. See section 9.2 of this Certificate.
Regulation: Regulation: Comment:	39(a)(i) 40(2)	Conservation measures Target carbon dioxide emission rate The products can contribute to minimising heat loss at jambs and sills. See sections 6.1 and 6.3 of this Certificate.

Construction (Design and Management) Regulations 2015

Construction (Design and Management) Regulations (Northern Ireland) 2016

In the opinion of the BBA, this Certificate does not include any content which relates to the obligations of the client, designer (including Principal Designer) and contractor (including Principal Contractor) under these Regulations.

Additional Information

NHBC Standards 2020

In the opinion of the BBA, Dacatie Supafix (SF), Supafix Fire Rated (SFR) and Supafix Multicloser Insulated PVC-U Cavity Closers, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements in relation *NHBC Standards*, Chapter 6.1 *External masonry walls*.

Technical Specification

1 Description

1.1 The Supafix (SF) and Supafix Multicloser closers comprise a PVC-U outer profile enclosing a closed-cell expanded polystyrene (EPS) core or extruded polystyrene (XPS) core.


1.2 The Supafix SFR (Fire Rated system) comprises a PVC-U outer profile enclosing a polythene-encapsulated mineral wool insulation.

1.3 Dacatie Supafix (SF), Supafix Fire Rated (SFR) and Supafix Multicloser Insulated PVC-U Cavity Closers are available in sizes to suit the cavity widths shown in Table 1 and Figure 1.

Closer type	Length (m)	Cavity width (mm)
Supafix (SF)	2.1 and 3	50, 55, 60, 65, 70, 75, 80, 85, 90, 95, 100, 105 and 110
Supafix Fire Rated (SFR)	2.4	50, 80, 90 and 100
Supafix Multicloser	2.4	50, 65, 75, 85 and 100 ⁽¹⁾

(1) Supplied with insulation pre-notched, to cut to the required cavity width.

Figure 1 Supafix closer (all dimensions in mm) (example sizes)




1.4 The PVC-U profiles include the following features:

- flanges that fit over both leaves of masonry
- flanges with nibs to aid plaster adhesion.

1.5 The Supafix range of closers are designed primarily for second fix applications when a frame former is not required. They can be simply pushed into position in the cavity and nailed⁽¹⁾ to the surrounding masonry (see Figure 2).

(1) Fixings outside the scope of this Certificate.

Figure 2 Typical jamb details



2 Manufacture

2.1 The cavity closer profiles are manufactured from unplasticised polyvinyl chloride (PVC-U) and are produced by conventional extrusion techniques. Insulation is cut to size and fitted manually in the factory, where necessary with the aid of an acrylic sealant.

2.2 As part of the assessment and ongoing surveillance of system quality, the BBA has:

- agreed with the manufacturer the quality control procedures and system testing to be undertaken
- assessed and agreed the quality control operated over batches of incoming materials
- monitored the production process and verified that it is in accordance with the documented process
- evaluated the process for management of nonconformities
- checked that equipment has been properly tested and calibrated
- undertaken to carry out the above measures on a regular basis through a surveillance process, to verify that the specifications and quality control operated by the manufacturer are being maintained.

2.3 The management system of Quantum Profile Systems Ltd has been assessed and registered as meeting the requirements of BS EN ISO 9001 : 2015 by SGS (Certificate GB92/1247) and BS EN ISO 14001 : 2015 by SGS (Certificate GB13/8840).

3 Delivery and site handling

3.1 Cavity closer profiles are delivered to site packed in polythene sleeves. Each pack carries an instruction leaflet bearing the marketing company's name and the BBA logo incorporating the number of this Certificate.

3.2 Packs of cavity closer profiles should be stored flat and under cover in a clean area away from direct sunlight and excessive heat, and supported along their length to prevent distortion or damage.

Assessment and Technical Investigations

The following is a summary of the assessment and technical investigations carried out on Dacatie Supafix (SF), Supafix Fire Rated (SFR) and Supafix Multicloser Insulated PVC-U Cavity Closers.

Design Considerations

4 General

4.1 Dacatie Supafix (SF), Supafix Fire Rated (SFR) and Supafix Multicloser Insulated PVC-U Cavity Closers are for use in masonry walls with nominal cavity widths in the range of 50 to 110 mm. The products close the cavity at openings

without forming a thermal bridge, and provide a damp-proof barrier between inner and outer wall leaves at the point of closure. The closers can only be incorporated into the wall after construction and prior to the installation of the window or door frame.

4.2 Masonry walls into which cavity closers are incorporated must be constructed in accordance with the national Building Regulations and one or more of the following technical specifications:

- BS 8000-0 : 2014
- BS 8000-3 : 2001
- BS EN 1996-1-1 : 2005 and its UK National Annex
- BS EN 1996-1-2 : 2005 and its UK National Annex
- BS EN 1996-2 : 2006 and its UK National Annex
- BS EN 1996-3 : 2006 and its UK National Annex
- PD 6697 : 2019.

4.3 The products are suitable for use with timber, PVC-U, aluminium or steel window and door frames. The closers are non-loadbearing, and window and door frames must be fixed independently to the masonry. Proprietary window and door frame fixings, which may be recommended by the Certificate holder, are outside the scope of this Certificate.

4.4 The products are intended for use in a flush jamb construction. However, with the small flange removed at the factory, the products may also be used in a check reveal application and to fit the window after completion of the masonry, as is conventional practice in some areas.

4.5 By virtue of the nibs down the length of the PVC-U flange, the products can provide a key for traditional plaster finishes (see also section 14.4).

5 Practicability of installation

The products are designed to be installed by a competent general builder, or a contractor, experienced with these types of products.

6 Hygrothermal behaviour



6.1 The products can contribute to maintaining continuity of thermal insulation at jambs and sills in wall openings. The path of minimum thermal resistance through the closers calculated to BRE Information Paper IP 8/08 is at least $0.45 \text{ m}^2 \cdot \text{K} \cdot \text{W}^{-1}$ when used in jambs and sills with the window/door frame set back 30 mm or more into the wall cavity (see Figure 2). Example junction details shown in Figure 2 are acceptable. For Accredited Construction Details, the corresponding heat loss rates ψ -values (psi) in BRE Information Paper IP 1/06, Table 3, may be used in carbon emission calculations in Scotland and Northern Ireland. Attention must be given to the correct setback in order to ensure compliance with these requirements. Detailed guidance on limiting heat loss and air infiltration can be found in the documents supporting the national Building Regulations.



6.2 Jambs and sills incorporating the products, in accordance with section 6.1, will adequately limit the risk of local surface condensation.



6.3 Under normal domestic conditions, the level of interstitial condensation associated with the products will be low and the risk of any resultant damage minimal.

6.4 Door frames installed with proprietary fixings which cannot be set back into the wall cavity by a minimum of 30 mm may require additional thermal insulation (for example, insulated dry lining) to minimise excessive heat loss and the risk of excessive surface condensation.

6.5 The junctions between the wall and the front and back of the window/door frame must be sealed effectively.

7 Weather resistance



7.1 The products are effective as a vertical damp-proof barrier at jambs of window and door openings in masonry constructions where a brick/block closer and damp-proof course (dpc) detail would normally be used. The closers are also effective as a horizontal damp-proof barrier at the sill or threshold.

7.2 In installations with a flush (in-line) wall opening and a minimum window setback of 30 mm (see section 6.1 and Figure 2), the products are suitable for use in the exposure zones 1 (sheltered), 2 (moderate) and 3 (severe), as depicted in the map in section 3.1 of BRE Report BR 262 : 2002. The closers may also be considered suitable for use in other locations where a conventional return brick/block closer detail with dpc has been found to provide adequate resistance to the penetration of wind-driven rain.

7.3 The products may also be used to construct a check reveal (see Figure 2). In this construction, in which the window is positioned in a rebate behind the outer leaf of the jamb, the products are suitable for use in exposure zones up to and including zone 4 (very severe), as depicted in the map shown in section 3.1 of BRE Report BR 262 : 2002, which covers all exposure zones in the United Kingdom.

8 Structural stability

8.1 The products are non-loadbearing and must not be used to support loads from the masonry. Lintels are required above window or door openings.

8.2 The products will not have an adverse effect on the structural stability of brickwork or blockwork walls constructed in the conventional manner in accordance with normal good practice as defined in the Standards listed in section 4.2 of this Certificate. Use of the products does not obviate the need for conventional wall ties around the openings.

8.3 Window and door frames should be fixed to the masonry by conventional means, in addition to any fixings to the closers⁽¹⁾.

(1) Outside the scope of this Certificate.

9 Properties in relation to fire

Dacatie Supafix (SF) and Supafix Multicloser

9.1 The products do not constitute a cavity barrier against the penetration of smoke and flame; therefore, they should be used in conjunction with cavity barriers, where required and in accordance with the requirements defined in the documents supporting the national Building Regulations.

Dacatie Supafix Fire Rated (SFR)



9.2 The Dacatie Supafix Fire Rated (SFR) closer was tested for fire resistance in accordance with BS 476-20 : 1987 and achieved the fire resistance ratings given in Table 2 of this Certificate, with respect to both integrity and insulation. It can therefore act as a cavity barrier for the specific constructions tested, where required by the documents supporting the national Building Regulations. Full details of the constructions tested and referenced in Table 2 are available from the Certificate holder.

Table 2 Integrity and insulation ratings for Dacatie Supafix Fire Rated (SFR) cavity closer

Maximum cavity width (mm)	Cavity closer details	Test Report ⁽¹⁾	Position of cavity closer	Integrity rating ⁽²⁾ (minutes)	Insulation rating ⁽²⁾ (minutes)
100	Dacatie Supafix Fire Rated (SFR) cavity closer (overall size 120 x 20 mm, mineral wool friction fitted into polythene sleeve, density 140 kg m ⁻³)	Test Report Warres No 126769, dated 18 December 2002	Vertically mounted ⁽³⁾ from the face exposed to the heating conditions of the test	60	60
			Vertically mounted ⁽⁴⁾ from the face unexposed to the heating conditions of the test	60	30
			Horizontally mounted ⁽³⁾ from the face exposed to the heating conditions of the test	30	30
			Horizontally mounted ⁽⁴⁾ from the face unexposed to the heating conditions of the test	60	15

- (1) Further details can be provided by the Certificate holder.
- (2) Test was discontinued after a period of 60 minutes.
- (3) Simulating fire in the cavity (fire break into compartment).
- (4) Simulating fire in the compartment (fire break out into the cavity).

9.3 Other versions of the products or constructions required to act as cavity barriers, as specified by the relevant national Building Regulations, must be assessed/tested in accordance with the requirements of the documents supporting the Regulations.

Dacatie Supafix (SF), Supafix Fire Rated (SFR) and Supafix Multicloser

9.4 The use of the products does not exclude the need to provide suitable fire protection to steel lintels where this is necessary to satisfy the requirements of the documents supporting the national Building Regulations.

10 Maintenance

To ensure the maximum weathertightness, the silicone seal between window or door frames and masonry must be checked regularly and repairs or renewal carried out promptly.

11 Durability



The products are durable and, when installed in accordance with this Certificate, will not suffer significant degradation when protected within the cavity. The products will continue to function for the normal expected life of the building in which they are installed.

12 Reuse and recyclability

The PVC-U profiles of the products can be recycled.

13 General

13.1 Installation of the Dacatie Supafix (SF), Supafix Fire Rated (SFR) and Supafix Multicloser Insulated PVC-U Cavity Closers must be carried out in accordance with the Certificate holder's instructions and this Certificate.

13.2 A cavity barrier may be required (see sections 9.1 and 9.3).

13.3 The appropriate closer is selected for the job (see sections 4.1 and 4.4).

13.4 Reference should be made to the typical installation details shown in Figure 2 when reading the installation details given in section 14. The windows shown in this Figure are for information only and do not form part of this assessment.

13.5 When installing the products, the exposed insulation should always be positioned against the inner leaf (see Figure 2).

13.6 In cutting the products to length, care should be taken to achieve clean, flat, square ends.

13.7 To comply with thermal requirements, the inner surface of the window/door frame must be set back at least 30 mm behind the outer leaf, and the junctions between the wall and the front and back of the window/door frame and sill sealed effectively (see section 6.1 and Figure 2 of this Certificate).

14 Procedure

14.1 The procedures for flush and rebated jambs are essentially the same as described in sections 14.5 to 14.7. However, for the rebated jambs application, the following should be noted:

- there is no flange at the base of the outer PVC-U jamb section to be removed
- the sill section should be cut to sill length, plus twice the rebated length
- the simple flange must sit on the internal skin and the front must butt up against the inside of the external skin
- where a timber window frame is used, a dpc strip should be positioned between the frame and outer leaf.

14.2 Appropriate insulated lintels and ancillary damp-proof protection are butted onto (but not supported by) the jamb closers at the head, and window/door frames are fixed to the outer leaf with proprietary fixings⁽¹⁾.

(1) Outside the scope of this Certificate.

14.3 An effective sealant is applied over a back-up strip between the front and back of the window/door frame and the inner and outer leaf.

14.4 Either wet plaster or a dry lining on plaster dabs is applied to the internal reveal. In locations where the plaster may be subject to repeated impact (eg at door reveals from door slamming), it is recommended that wet plaster is reinforced by hessian scrim or, preferably, replaced by dry lining.

Closer built-in after construction of wall, and prior to installation of window or door (second fix)

14.5 The closers can only be incorporated into the wall after construction and prior to the installation of the window or door frame.

14.6 A section of closer is cut to length and pushed into the sill cavity, ensuring correct orientation (exposed insulation towards the internal skin).

14.7 The jamb closers are cut 50 mm longer than the sill closer. When using multi width cavity closers, the insulation is cut to the cavity width. The PVC-U flanges are cut away at the base of the closer, which is subsequently pushed into the cavity, propped in a vertical position and butted against the sill closer, with the cut flanges seated on the masonry at sill level. The closer is secured (jamb section only) to the masonry through the flange, using galvanized or non-ferrous clout nails⁽¹⁾.

(1) Outside the scope of this Certificate.

Closer built-in with window or door frame

14.8 The closers may be incorporated into the wall after pre-fixing to the window or door frame.

14.9 The closer lengths are cut as described in sections 14.6 and 14.7 and the closer secured to the window or door frame through the PVC-U flange (or body of the closer), using galvanized or non-ferrous clout nails⁽¹⁾ (timber frame), or self-tapping screws⁽¹⁾ (PVC-U or metal frame).

(1) Outside the scope of this Certificate.

14.10 The window or door frame with closers attached is positioned with the sill closer in the cavity. The masonry is built up around the window/door frame and jamb closer assembly, and the installation completed as described in sections 14.2 to 14.4.

Refurbishment

14.11 The closers are suitable for use in refurbishment work. For this application, the opening must first be 'cleaned' ready to take the new closer.

14.12 The closer lengths are cut as described in sections 14.6 and 14.7, inserted into the cavity (jamb sections before sill) and secured (jamb section only) to the masonry through the flange using galvanized or non-ferrous clout nails⁽¹⁾.

(1) Outside the scope of this Certificate.

14.13 The window or door frame is then fixed to masonry (fixings outside the scope of this Certificate) and the installation completed as described in sections 14.2 and 14.3.

Technical Investigations

15 Tests

Tests were carried out on the PVC-U extrusions to determine:

- shrinkage on heating
- gelation by immersion in acetone.

16 Investigations

16.1 An assessment was made of:

- heat loss and condensation risk
- weather resistance of the products
- the practicability of the installation
- fire resistance and structural stability of walls incorporating the products
- durability of the components used in the construction of the products.

16.2 The manufacturing process was evaluated, including the methods adopted for quality control, and details were obtained of the quality and compositions of material used.

Bibliography

BRE Information Paper IP 1/06 *Assessing the effects of thermal bridging at junctions and around openings*

BRE Information Paper IP 8/08 *Determining the minimum thermal resistance of cavity closers*

BRE Report BR 262 : 2002 *Thermal insulation : avoiding risks*

BS 476-20 : 1987 *Fire tests on building materials and structures — Method for determination of the fire resistance of elements of construction (general principles)*

BS 8000-0 : 2014 *Workmanship on construction sites — Introduction and general principles*

BS 8000-3 : 2001 *Workmanship on sites — Code of practice for masonry*

BS EN 1996-1-1 : 2005 + A1 : 2012 *Eurocode 6 : Design of masonry structures — General rules for reinforced and unreinforced masonry structures*

NA to BS EN 1996-1-1 : 2005 + A1 : 2012 UK National Annex to *Eurocode 6 : Design of masonry structures — General rules for reinforced and unreinforced masonry structures*

BS EN 1996-1-2 : 2005 *Eurocode 6 : Design of masonry structures — General rules — Structural fire design*

NA to BS EN 1996-1-2 : 2005 UK National Annex to *Eurocode 6 : Design of masonry structures — General rules — Structural fire design*

BS EN 1996-2 : 2006 *Eurocode 6 : Design of masonry structures — Design considerations, selection of materials and execution of masonry*

NA to BS EN 1996-2 : 2006 UK National Annex to *Eurocode 6 : Design of masonry structures — Design considerations, selection of materials and execution of masonry*

BS EN 1996-3 : 2006 *Eurocode 6 : Design of masonry structures — Simplified calculation methods for unreinforced masonry structures*

NA to BS EN 1996-3 : 2006 UK National Annex to *Eurocode 6 : Design of masonry structures — Simplified calculation methods for unreinforced masonry structures*

BS EN ISO 9001 : 2015 *Quality management systems — Requirements*

BS EN ISO 14001 : 2015 *Environmental management systems — Requirements with guidance for use*

PD 6697 : 2019 *Recommendations for the design of masonry structures to BS EN 1996-1-1 and BS EN 1996-2*

17 Conditions

17.1 This Certificate:

- relates only to the product/system that is named and described on the front page
- is issued only to the company, firm, organisation or person named on the front page – no other company, firm, organisation or person may hold or claim that this Certificate has been issued to them
- is valid only within the UK
- has to be read, considered and used as a whole document – it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English Law.

17.2 Publications, documents, specifications, legislation, regulations, standards and the like referenced in this Certificate are those that were current and/or deemed relevant by the BBA at the date of issue or reissue of this Certificate.

17.3 This Certificate will remain valid for an unlimited period provided that the product/system and its manufacture and/or fabrication, including all related and relevant parts and processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

17.4 The BBA has used due skill, care and diligence in preparing this Certificate, but no warranty is provided.

17.5 In issuing this Certificate the BBA is not responsible and is excluded from any liability to any company, firm, organisation or person, for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system or any other product/system
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product/system
- actual installations of the product/system, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product/system is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product/system, including its manufacture, supply, installation, use, maintenance and removal
- any claims by the manufacturer relating to CE marking.

17.6 Any information relating to the manufacture, supply, installation, use, maintenance and removal of this product/system which is contained or referred to in this Certificate is the minimum required to be met when the product/system is manufactured, supplied, installed, used, maintained and removed. It does not purport in any way to restate the requirements of the Health and Safety at Work etc. Act 1974, or of any other statutory, common law or other duty which may exist at the date of issue or reissue of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care.